

TEST REPORT FOR EKO-OKNA S.A.

Report No.: J7777.01-250-44

Date: 07/17/19 Revision 1: 07/18/19



SECTION 1

SCOPE

Intertek Building & Construction (B&C) was contracted by Eko-Okna S.A. to perform testing in accordance with AAMA/WDMA/CSA 101/I.S.2/A440 and AAMA 910 on their Salamander bluEvolution 82 Inswing Casement Window. Results obtained are tested values and were secured by using the designated test method(s). Testing was conducted at the Intertek B&C test facility in Windham, NH. This report does not constitute certification of this product nor an opinion or endorsement by this laboratory.


SECTION 2

SUMMARY OF TEST RESULTS

TITLE	RESULTS
AAMA/WDMA/CSA 101/I.S.2/A440-11	Class-AW PG100 899 x 1499 (35-3/8 x 59)-CW
Design Pressure	±4800 Pa (±100.25 psf)
Air Infiltration	<0.05 L/s/m ² (<0.01 cfm/ft ²)
Water Penetration Resistance Test Pressure	580 Pa (12.11 psf)

For INTERTEK B&C:

COMPLETED BY:	Kevin McNeil
TITLE:	Project Lead
SIGNATURE:	
DATE:	07/18/19

REVIEWED BY:	Brian Philcrantz
TITLE:	Laboratory Manager
SIGNATURE:	
DATE:	07/18/19

cns:bp

This report is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this report. Only the Client is authorized to permit copying or distribution of this report and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test results in this report are relevant only to the sample(s) tested. This report by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.