

TEST REPORT FOR EKO-OKNA S.A.

Report No.: J7774.01-250-44

Date: 07/23/19



SECTION 1

SCOPE

Intertek Building & Construction (B&C) was contracted by Eko-Okna S.A. to perform testing in accordance with AAMA/WDMA/CSA 101/I.S.2/A440 on their Ideal 4000 Tilt/Turn Casement Window. Results obtained are tested values and were secured by using the designated test method(s). Testing was conducted at the Intertek B&C test facility in Windham, NH. This report does not constitute certification of this product nor an opinion or endorsement by this laboratory.


SECTION 2

SUMMARY OF TEST RESULTS

TITLE	RESULTS
AAMA/WDMA/CSA 101/I.S.2/A440-11	Class-CW PG50 1200 x 1800 (47-1/4 x 71)-CW
Design Pressure	±2400 Pa (±50.13 psf)
Air Infiltration	<0.05 L/s/m ² (<0.01 cfm/ft ²)
Water Penetration Resistance Test Pressure	580 Pa (12.11 psf)

For INTERTEK B&C:

COMPLETED BY:	Kevin McNeil
TITLE:	Project Lead
SIGNATURE:	
DATE:	07/23/19

REVIEWED BY:	Brian Philcrantz
TITLE:	Laboratory Manager
SIGNATURE:	
DATE:	07/23/19

cns:bp